



NOTES:

- 1) All piping for the assembly should be threaded or solvent welded joints. Sch. 80 PVC, brass or type K copper.
- 2) Adequate support is required for all new installations.
- 3) All nuts and bolts shall be stainless steel.
- 4) All assemblies require 2 unions to allow the backflow preventer to be removed without cutting the pipe.